

Annex to declaration of accreditation (scope of accreditation)  
 Normative document: EN ISO/IEC 17020:2012  
 Registration number: **I 327, type A**

of **DEKRA Certification B.V**

This annex is valid from: **21-04-2022 to 01-05-2026**

Replaces annex dated: **23-09-2021**

**Location(s) where activities are performed under accreditation**

**Head Office**

Meander 1051  
 6825 MJ  
 Arnhem  
 The Netherlands

| Location   | Abbreviation/ location code |
|--|-----------------------------|
| Meander 1051<br>6825 MJ<br>Arnhem<br>The Netherlands | A.                          |

| No.                 | Field of inspection | Type and range of inspection  | Methods & procedures <sup>1</sup>   | Location |
|---------------------|---------------------|---|---|----------|
| <b>Transformers</b> |                     |   |   |          |
| 1                   | Power transformers  | Inspection by witnessing of tests execution<br><br>Evaluate the results obtained by these tests | NEN-EN-IEC 60076-1<br>NEN-EN-IEC 60076-2<br>NEN-EN-IEC 60076-3<br>NEN-EN-IEC 60076-4<br>NEN-EN-IEC 60076-5<br>NEN-EN-IEC 60076-6<br>NEN-EN-IEC 60076-10<br>NEN-EN-IEC 60076-11<br>NEN-EN-IEC 60076-15 | A.       |

<sup>1</sup> If no date or version number is mentioned for a normative document, the accreditation concerns the most current version of the document or scheme.

<sup>1</sup> If there is a referral to a code starting with NAW, NAP, EA or IAF, this concerns a scheme mentioned on the [RvA-BR010-lijst](#).

This annex has been approved by the Board of the  
 Dutch Accreditation Council, on its behalf,

J.A.W.M. de Haas

Annex to declaration of accreditation (scope of accreditation)  
 Normative document: EN ISO/IEC 17020:2012  
 Registration number: **I 327, type A**

of **DEKRA Certification B.V**

This annex is valid from: **21-04-2022 to 01-05-2026**

Replaces annex dated: **23-09-2021**

| No.               | Field of inspection  | Type and range of inspection  | Methods & procedures <sup>1</sup>  | Location |
|-------------------|--|---|--|----------|
| 2                 | Current transformers                                       |   | NEN-EN-IEC 61869-1<br>NEN-EN-IEC 61869-2<br>NEN-EN-IEC 61869-4<br>NEN-EN-IEC 60044-1<br>NEN-EN-IEC 60044-3   | A.       |
| 3                 | Voltage transformers                                       |   | NEN-EN-IEC 61869-1<br>NEN-EN-IEC 61869-3<br>NEN-EN-IEC 61869-4<br>NEN-EN-IEC 61869-5<br>NEN-EN-IEC 60044-2<br>NEN-EN-IEC 60044-3<br>NEN-EN-IEC 60044-5<br>NEN-EN-IEC 60044-6 | A.       |
| <b>Switchgear</b> |  |   |  |          |
| 4                 | Metal-enclosed AC switchgear<br>1-52 kV resp. $\geq 52$ kV | Inspection by witnessing of tests execution<br><br>Evaluate the results obtained by these tests | NEN-EN-IEC 62271-1<br>NEN-EN-IEC 62271-100<br>NEN-EN-IEC 62271-101<br>NEN-EN-IEC 62271-103<br>NEN-EN-IEC 62271-104<br>NEN-EN-IEC 62271-110<br>NEN-EN-IEC 62271-200           |          |
| 5                 | Insulation-enclosed AC switchgear                          |   | NEN-EN-IEC 62271-1<br>NEN-EN-IEC 62271-101<br>NEN-EN-IEC 62271-110<br>NEN-EN-IEC 62271-201   |          |
| 6                 | Gas insulated metal-enclosed AC switchgear (GIS)           |   | NEN-EN-IEC 62271-1<br>NEN-EN-IEC 62271-101<br>NEN-EN-IEC 62271-110<br>NEN-EN-IEC 62271-203   |          |

Annex to declaration of accreditation (scope of accreditation)

Normative document: EN ISO/IEC 17020:2012

Registration number: **I 327, type A**

of **DEKRA Certification B.V**

This annex is valid from: **21-04-2022 to 01-05-2026**

Replaces annex dated: **23-09-2021**

| No. | Field of inspection                                       | Type and range of inspection | Methods & procedures <sup>1</sup>  | Location |
|-----|---|------------------------------|--|----------|
| 7   | High Voltage AC circuit breakers                          |                              | NEN-EN-IEC 62271-1<br>NEN-EN-IEC 62271-100<br>NEN-EN-IEC 62271-101<br>NEN-EN-IEC 62271-110                         |          |
| 8   | High-voltage AC disconnectors and earthing switches       |                              | NEN-EN-IEC 62271-1<br>NEN-EN-IEC 62271-101<br>NEN-EN-IEC 62271-102<br>NEN-EN-IEC 62271-108<br>NEN-EN-IEC 62271-110 |          |
| 9   | High Voltage AC Switch-Fuse Combinations                  |                              | NEN-EN-IEC 62271-1<br>NEN-EN-IEC 62271-101<br>NEN-EN-IEC 62271-105<br>NEN-EN-IEC 62271-107<br>NEN-EN-IEC 62271-110 |          |
| 10  | High Voltage AC Contactors, Controller and Motor Starters |                              | NEN-EN-IEC 62271-1<br>NEN-EN-IEC 62271-101<br>NEN-EN-IEC 62271-106<br>NEN-EN-IEC 62271-110                         |          |
| 11  | High Voltage AC Capacitor by-pass switches                |                              | NEN-EN-IEC 62271-1<br>NEN-EN-IEC 62271-101<br>NEN-EN-IEC 62271-109<br>NEN-EN-IEC 62271-110                         |          |

of **DEKRA Certification B.V**

This annex is valid from: **21-04-2022 to 01-05-2026**

Replaces annex dated: **23-09-2021**

| No. | Field of inspection  | Type and range of inspection | Methods & procedures <sup>1</sup>   | Location |
|-----|--|------------------------------|---|----------|
| 12  | High Voltage AC Automatic circuit reclosers and fault interruptors |                              | NEN-EN-IEC 62271-1<br>NEN-EN-IEC 62271-101<br>NEN-EN-IEC 62271-110<br>NEN-EN-IEC 62271-111<br>IEEE C37.60 |          |
| 13  | High-voltage/low-voltage prefabricated substation                  |                              | NEN-EN-IEC 62271-1<br>NEN-EN-IEC 62271-101<br>NEN-EN-IEC 62271-110<br>NEN-EN-IEC 62271-202                |          |
| 14  | Rigid gas-insulated transmission lines                             |                              | NEN-EN-IEC 62271-1<br>NEN-EN-IEC 62271-204<br>IEEE C37.23   |          |
| 15  | High Voltage AC Switchgear assemblies                              |                              | NEN-EN-IEC 62271-1<br>NEN-EN-IEC 62271-101<br>NEN-EN-IEC 62271-110<br>NEN-EN-IEC 62271-205                |          |

**Insulators, Arresters**

|    |                                   |   |   |    |
|----|-----------------------------------|---|---|----|
| 16 | Insulators and insulated bushings | Inspection by witnessing of tests execution<br><br>Evaluate the results obtained by these tests | NEN-EN-IEC 62155<br>IEC 60137<br>IEC 60383-1<br>IEC 60383-2<br>IEC 61109  | A. |
| 17 | Surge arresters                   |   | NEN-EN-IEC 60099-1<br>IEC 60099-3<br>NEN-EN-IEC 60099-4<br>IEC 60099-6<br>IEC 60099-7<br>NEN-EN-IEC 60099-8<br>IEC 60099-9<br>IEEE C62.11 | A. |

**Cables**

Annex to declaration of accreditation (scope of accreditation)  
 Normative document: EN ISO/IEC 17020:2012  
 Registration number: **I 327, type A**

of **DEKRA Certification B.V**

This annex is valid from: **21-04-2022 to 01-05-2026**

Replaces annex dated: **23-09-2021**

| No.                                   | Field of inspection | Type and range of inspection  | Methods & procedures <sup>1</sup>  | Location |
|---------------------------------------|---------------------|---|--|----------|
| 18                                    | Cables              | Inspection by witnessing of tests execution<br><br>Evaluate the results obtained by these tests | AEIC CS9<br>AEIC CS4<br>ANSI/ICEA S-94-649<br>ANSI/ICEA S-97-682<br>IEC 60055-1<br>IEC 60055-2<br>IEC 60092-354<br>IEC 60141-1<br>IEC 60141-2<br>IEC 60141-3<br>IEC 60141-4<br>IEC 60502-1<br>IEC 60502-2<br>IEC 60840<br>IEC 62067<br>IEC 61089<br>HD 620<br>HD 621<br>HD 622<br>HD 632<br>BS 6622<br>BS 7835 | A.       |
| 19                                    | Cable accessories   |   | AEIC CS9<br>IEC 60055-1<br>IEC 60141-1<br>IEC 60141-2<br>IEC 60141-3<br>IEC 60141-4<br>IEC 60502-1<br>IEC 60502-2<br>IEC 60840<br>IEC 61238-1<br>IEC 62067<br>IEC 61284<br>IEEE 48<br>IEEE 404<br>IEC 62271-209  | A.       |
| <b>Medium- and High Voltage Fuses</b> |                     |   |  |          |
| 20                                    | Fuses               | Inspection by witnessing of tests execution<br><br>Evaluate the results obtained by these tests | ANSI / IEEE C37.41   | A.       |