

Annex to declaration of accreditation (scope of accreditation)
Normative document: EN ISO/IEC 17025:2017
Registration number: **L 505**

of **Peutz B.V.**
Laboratorium voor Brandveiligheid

This annex is valid from: **05-07-2023** to **01-03-2024**

Replaces annex dated: **08-02-2023**

Location(s) where activities are performed under accreditation

Head Office

Lindenlaan 41
6584 AC
Molenhoek (Limburg)
The Netherlands

Location	Abbreviation/ location code
Lindenlaan 41 6584 AC Molenhoek (Limburg) The Netherlands	MOL
Klopsteen 4a 5443 PW Haps The Netherlands	HAPS

No.	Material or product	Type of activity¹	Internal reference number	Location
1.	Various building parts and installations, partitions, ceilings, doors and shutters, floors and roofs, straight joints and seams, seals for penetrations	Fire resistance tests on building components and installations	HKL-B0.1 NEN 6069	HAPS
2.	Non-loadbearing elements: Walls	Fire resistance tests	HKL-B1.1 EN 1364-1, EN 1363-1 and EN 1363-2	HAPS

This annex has been approved by the Board of the Dutch Accreditation Council, on its behalf,

J.A.W.M. de Haas

¹ If there is a referral to a code starting with NAW, NAP, EA or IAF, this concerns a scheme mentioned on the [RvA-BR010-lst](#).
If no date or version number is mentioned for a normative document, the accreditation concerns the most current version of the document or scheme.

Annex to declaration of accreditation (scope of accreditation)
 Normative document: EN ISO/IEC 17025:2017
 Registration number: **L 505**

of **Peutz B.V.**
Laboratorium voor Brandveiligheid

This annex is valid from: **05-07-2023** to **01-03-2024**

Replaces annex dated: **08-02-2023**

No.	Material or product	Type of activity ¹	Internal reference number	Location
3.	Non-loadbearing elements: Ceilings	Fire resistance tests	HKL-B1.2 EN 1364-2, EN 1363-1 and EN 1363-2	HAPS
4.	Doors, shutters and openable windows		HKL-B3.1 EN 1634-1, EN 1634-2, EN 1363-1 and EN 1363-2	HAPS
5.	Load bearing elements: Floors and roofs		HKL-B2.1 EN 1365-2, EN 1363-1 and EN 1363-2	HAPS
6.	Service installations: linear joint seals		HKL-B4.1 EN 1366-4, EN 1363-1 and EN 1363-2	HAPS
7.	Service installations: Penetration seals		HKL-B4.2 EN 1366-3, EN 1363-1 and EN 1363-2	HAPS
8.	Building products	Reaction to fire test; SBI methode	HKL-B5.1 EN 13823	HAPS
9.		Reaction to fire test; small flame	HKL-B5.2 EN ISO 11925-2	HAPS
10.		Determination of the heat of combustion; bomb calorimeter	HKL-B5.3 EN ISO 1716:2018 and EN ISO 1716:2010	HAPS
11.	Doors and shutters	Determination and classification of the smoke leakage	HKL-B6.1 EN 1634-3 and EN 13501-2	MOL
12.	Construction products and building elements	Testing and classification of fire resistance for tests related to this scope	HKL-B8.1 EN 13501-2, EN 1364-1, EN 1364-2, EN 1634-1, EN 1365-2, EN 1366-3 and EN 1366-4	HAPS
13.	Building products	Testing and classification of fire resistance for tests related to this scope	HKL-B8.2 EN 13501-1, EN 13823, EN ISO 11925-2 EN ISO 1716:2018 and EN ISO 1716:2010	HAPS

Annex to declaration of accreditation (scope of accreditation)
 Normative document: EN ISO/IEC 17025:2017
 Registration number: **L 505**

of **Peutz B.V.**
Laboratorium voor Brandveiligheid

This annex is valid from: **05-07-2023** to **01-03-2024**

Replaces annex dated: **08-02-2023**

Opinions and interpretations

14.	Non-loadbearing constructions or elements, loadbearing constructions or elements, service installations and doors, shutters and openable windows	Extended application (EXAP) of testing of fire resistance (EN 1364-1, EN 1364-2, EN 1365-2, EN 1366-3, EN 1366-4 and EN 1634-1)	HKL-B7.1 EN 15725, prEN 15254-1, EN 15254-2, EN 15254-3, EN 15254-4, EN15254-5, EN 15254-7, EN 15882-3, EN 15882-4, EN 15269-1, EN 15269-2, EN 15269-3, prEN 15269-4, EN 15269-5, prEN 15269-6, EN 15269-7, EN 15269-10 and EN 15269-11	HAPS
15.	Building products	Extended application (EXAP) of testing of reaction to fire (EN 13823, EN ISO 11925-2, EN ISO 1716:2010 and EN ISO 1716:2018)	HKL-B7.1 EN 15725 and CEN/TS 15117	HAPS
16.	Doors and shutters, operable textile screens and openable windows	Extended application (EXAP) of testing smoke leakage (EN 1634-3)	HKL-B7.1 EN 15725, EN 15269-1 and EN 15269-20	HAPS

Annex to declaration of accreditation (scope of accreditation)
 Normative document: EN ISO/IEC 17025:2017
 Registration number: **L 505**

of **Peutz B.V.**
Laboratorium voor Brandveiligheid

This annex is valid from: **05-07-2023** to **01-03-2024**

Replaces annex dated: **08-02-2023**

The accreditation for the activities below is suitable for notification.

European construction products regulation No 305/2011
 System 3 Verification

Product areas: **2, 4, 7, 14, 19, 21, 22, 30 and 35**

Decision: 95/467/EG		EN 12859:2011; EN 520:2004 + A1:2009		
GYPSUM PRODUCTS (1/4)				
17.	Plasterboards and ceiling elements with thin laminations, fibrous gypsum boards, and composite panels (laminates) in which the incorporated material is placed on a face susceptible to be exposed to fire, including relevant ancillary products. In walls, partitions or ceilings (or lining thereof) subject to reaction to fire requirements	Testing and classification of reaction to fire	HKL B5.1/HKL B5.2/HKL B5.3/B8.2 EN 13823 EN ISO 11925-2 EN 13501-1 EN ISO 1716	HAPS

Annex to declaration of accreditation (scope of accreditation)
 Normative document: EN ISO/IEC 17025:2017
 Registration number: **L 505**

of **Peutz B.V.**
Laboratorium voor Brandveiligheid

This annex is valid from: **05-07-2023** to **01-03-2024**

Replaces annex dated: **08-02-2023**

Decision: 95/467/EG GYPSUM PRODUCTS (2/4)		EN 12859:2011; EN 520:2004 + A1:2009		
18.	Plasterboards and ceiling elements with thin laminations, fibrous gypsum boards, fibrous gypsum plaster casts, and composite panels (laminates), in which the incorporated material is placed on a face susceptible to be exposed to fire, including relevant ancillary products (in walls, partitions or ceilings (or lining thereof) subject to reaction to fire requirements)	Testing and classification of fire resistance	HKL B1.1/HKL B2.1/HKL B8.1 EN 1364-1 EN 1365-2 EN 1363-1 EN 1363-2 EN 13501-2	HAPS
Decision: 98/213/EG INTERNAL PARTITION KITS (1/4)		EAD 090010-00-0404; EAD 210005-00-0505		
19.	Internal partition kits (for uses subject to reaction to fire requirements)	Testing and classification of reaction to fire	HKL B5.1/HKL B5.2/HKL B5.3/B8.2 EN 13823 EN ISO 11925-2 EN 13501-1 EN ISO 1716	HAPS
Decision: 98/213/EG STRUCTURAL SEALANT GLAZING KITS (2/5)		EAD 090010-00-0404		
20.	Structural sealant glazing kits (Fire partitioning)	Testing and classification of fire resistance	HKL B8.1 EN 13501-2 EN 1363-1 EN 1363-2	HAPS

Annex to declaration of accreditation (scope of accreditation)
 Normative document: EN ISO/IEC 17025:2017
 Registration number: **L 505**

of **Peutz B.V.**
Laboratorium voor Brandveiligheid

This annex is valid from: **05-07-2023** to **01-03-2024**

Replaces annex dated: **08-02-2023**

Decision: 99/93/EC DOORS, WINDOWS, SHUTTERS, BLINDS, GATES AND RELATED BUILDING HARDWARE (1/1)		EN 1125:2008; EN 1154:1996/A1:2002; EN 1154:1996/A1:2002/AC:2006; EN 1155:1996/A1:2002/AC:2006; EN 1155:1997/A1:2002; EN 1158:1997/A1:2002; EN 1158:1997/A1:2002/AC:2006; EN 179:2008; EN 1935:2002; EN 1935:2002/AC:2003; EN 13830:2003		
21.	Building hardware related to doors, gates and windows (any other)	Testing and classification of fire resistance	HKL B3.1/HKL B6.1/HKL B8.2 EN 13501-2 EN 1634-1 EN 1634-3	HAPS
Decision: 2000/245/EC FLAT GLASS, PROFILED GLASS AND GLASS-BLOCK PRODUCTS (1/6)		EN 1279-5:2005+A2:2010; EN 1279-5:2018; EN 1096-4:2004; EN 1096-4:2018; EN 12150-2:2004; EN 12337-2:2004; EN 13024-2:2004; EN 14178-2:2004; EN 14179-2:2005; EN 14321-2:2005; EN 14449:2005; EN 14449:2005/AC:2005; EN 1748-1-2:2004; EN 1748-2-2:2004;EN 1863-2:2004; EN 572-9:2004		
22.	Flat or curved glass panels (for uses subject to external fire performance regulations)	Testing and classification of fire resistance	HKL B1.1/HKL B2.1/HKL B8.1 EN 13501-2 EN 1364-1 EN 1365-2 EN 1363-1 EN 1363-2	HAPS
Decision: 2000/245/EC FLAT GLASS, PROFILED GLASS AND GLASS-BLOCK PRODUCTS (2/6)		EN 1279-5:2005+A2:2010; EN 1279-5:2018; EN 12758		
23.	Flat or curved glass panels Channel-shaped glass Insulating glass units Glass blocks Glass-block wall panels (for uses subject to reaction to fire regulations)	Testing and classification of reaction to fire	HKL B5.1/HKL B5.2/HKL B5.3/B8.2 EN 13823 EN ISO 11925-2 EN 13501-1 EN ISO 1716	HAPS

Annex to declaration of accreditation (scope of accreditation)
 Normative document: EN ISO/IEC 17025:2017
 Registration number: **L 505**

of **Peutz B.V.**
Laboratorium voor Brandveiligheid

This annex is valid from: **05-07-2023** to **01-03-2024**

Replaces annex dated: **08-02-2023**

Decision: 2000/245/EC				
FLAT GLASS, PROFILED GLASS AND GLASS-BLOCK PRODUCTS (3/6)		EN 1279-5:2005+A2:2010; EN 1279-5:2018; EN 12758		
24.	Flat glass Profiled glass Glass block products Channel-shaped glass (for uses subject to external fire performance regulations)	Testing and classification of fire resistance	HKL B1.1/HKL B2.1/HKL B8.1 EN 13501-2 EN 1364-1 EN 1365-2 EN 1363-1 EN 1363-2	HAPS
Decision: 98/213/EC				
INTERNAL PARTITION KITS (2/5)		EAD 210005-00-0505		
25.	Internal partition kits for use as non-loadbearing walls (Fire partitioning)	Testing and classification of fire resistance	HKL B1.1/HKL B8.1 EN 1363-1 EN 1363-2 EN 1364-1 EN 13501-2	HAPS
Decision: 99/454/EC				
FIRE STOPPING, FIRE SEALING AND FIRE PROTECTIVE PRODUCTS (2/2)		EAD 350402-00-1106; EAD 350140-00-1106, EAD 350142-00-1106 EAD 350454-00-1104; EAD 350141-00-1106; ETAG 026-4; ETAG 026-5		
26.	Fire stopping and fire sealing products Fire protective products (including coatings)	Testing and classification of reaction to fire	HKL B5.1/HKL B5.2/HKL B5.3/B8.2 EN 13823 EN ISO 11925-2 EN 13501-1 EN ISO 1716	HAPS

Annex to declaration of accreditation (scope of accreditation)
 Normative document: EN ISO/IEC 17025:2017
 Registration number: **L 505**

of **Peutz B.V.**
Laboratorium voor Brandveiligheid

This annex is valid from: **05-07-2023** to **01-03-2024**

Replaces annex dated: **08-02-2023**

Decision: 99/454/EC FIRE STOPPING, FIRE SEALING AND FIRE PROTECTIVE PRODUCTS (2/2)		EAD 350454-00-1104		
27.	Fire stopping and fire sealing products Fire protective products (including coatings)	Testing and classification of fire resistance	HKL B4.2/HKL B8.1 EN 1366-3 EN 1363-1 EN 1363-2 EN 13501-2	HAPS
Decision: 99/454/EC FIRE STOPPING, FIRE SEALING AND FIRE PROTECTIVE PRODUCTS (2/2)		EAD 350141-00-1106; ETAG 026-5		
28.	Fire stopping and fire sealing products Fire protective products (including coatings)	Testing and classification of fire resistance	HKL B4.1/HKL B8.1 EN 1366-4 EN 1363-1 EN 1363-2 EN 13501-2	HAPS
Decision: 99/454/EC FIRE STOPPING, FIRE SEALING AND FIRE PROTECTIVE PRODUCTS (2/2)		ETAG 026-4		
29.	Fire stopping and fire sealing products Fire protective products (including coatings)	Testing and classification of fire resistance	HKL B1.1/HKL B1.2/HKL B3.1/HKL B8.1 EN 1364-1 EN 1364-2 EN 1634-1 EN 13501-2	HAPS

Annex to declaration of accreditation (scope of accreditation)
 Normative document: EN ISO/IEC 17025:2017
 Registration number: **L 505**

of **Peutz B.V.**
Laboratorium voor Brandveiligheid

This annex is valid from: **05-07-2023** to **01-03-2024**

Replaces annex dated: **08-02-2023**

Decision: 98/436/EC		EN 1873:2005		
ROOF COVERINGS, ROOFLIGHTS, ROOF WINDOWS AND ANCILLARY PRODUCTS (2/6)				
30.	Flat and profiled sheets Roofing tiles, slates, stones and shingles Factory-bonded composite or sandwich panels Rooflights Roof windows Fascias and soffit boards (for uses subject to reaction to fire regulations)	Testing and classification of reaction to fire	HKL B5.1/HKL B5.2/HKL B5.3/B8.2 EN 13823 EN ISO 11925-2 EN 13501-1 EN ISO 1716	HAPS
Decision: 97/462/EG		EN 13986:2004+A1:2015		
WOOD-BASED PANELS (2/2)				
31.	Unfaced, overlaid and veneered or coated wood-based panels For non structural elements in internal or external applications	Testing and classification of reaction to fire	HKL B5.1/HKL B5.2/HKL B5.3/B8.2 EN 13823 EN ISO 11925-2 EN 13501-1 EN ISO 1716	HAPS

Annex to declaration of accreditation (scope of accreditation)
 Normative document: EN ISO/IEC 17025:2017
 Registration number: **L 505**

of **Peutz B.V.**
Laboratorium voor Brandveiligheid

This annex is valid from: **05-07-2023** to **01-03-2024**

Replaces annex dated: **08-02-2023**

Decision: 99/91/EC		EN 13162: 2012+A1:2015		
THERMAL INSULATING PRODUCTS (2/2)		EN 13164: 2012+A1:2015		
32.	Thermal insulating products (factory-made products and products intended to be formed in-situ) (for uses subject to regulations on reaction to fire)	Testing and classification of reaction to fire	HKL B5.1/HKL B5.2/HKL B5.3/B8.2 EN 13823 EN ISO 11925-2 EN 13501-1 EN ISO 1716	HAPS
Decision: 98/437/EC		EN 13964:2004/A1:2006 EN 13964:2014		
INTERNAL AND EXTERNAL WALL AND CEILING FINISHES(3/5)		EN 14509:2013 EN 14716:2004		
33.	Coverings in roll form Linings Shingles Cladding slabs Suspended ceilings (kits) Tiles Sidings Panels Featured profiles Suspending frames	Testing and classification of reaction to fire	HKL B5.1/HKL B5.2/HKL B5.3/B8.2 EN 13823 EN ISO 11925-2 EN 13501-1 EN ISO 1716	HAPS

Annex to declaration of accreditation (scope of accreditation)
Normative document: EN ISO/IEC 17025:2017
Registration number: **L 505**

of **Peutz B.V.**
Laboratorium voor Brandveiligheid

This annex is valid from: **05-07-2023** to **01-03-2024**

Replaces annex dated: **08-02-2023**

Decision: 98/600/EC				
SELF-SUPPORTING TRANSLUCENT ROOF KITS (EXCEPT GLASS-BASED KITS) (3/3)		EAD 220089-00-0401		
34.	Self-supporting translucent roof kits (except glass-based kits)	Testing and classification of reaction to fire	HKL B5.1/HKL B5.2/HKL B5.3/B8.2 EN 13823 EN ISO 11925-2 EN 13501-1 EN ISO 1716	HAPS

Annex to declaration of accreditation (scope of accreditation)
 Normative document: EN ISO/IEC 17025:2017
 Registration number: **L 505**

of **Peutz B.V.**
Laboratorium voor Brandveiligheid

This annex is valid from: **05-07-2023** to **01-03-2024**

Replaces annex dated: **08-02-2023**

Decision: 97/808/EC		EN 14342:2013		
FLOORINGS (2/2)				
35.	<p>Rigid flooring products</p> <p>a) Components: Paving units, tiles, mosaics, parquet, decking of mesh or sheet, floor gratings, rigid laminated floorings, wood based products</p> <p>b) load bearing systems put on the market as kits</p> <p>Raised access floors; cavity floors</p> <p>Resilient and textile floorings</p> <p>Homogeneous and heterogeneous resilient floor coverings supplied either in tile, sheet or roll form (textile floor covering including tiles; plastic and rubber sheets (aminoplastic thermosetting floorings); linoleum and cork; anti-static sheet; floor loose laid tiles; resilient laminated floorings)</p>	Testing and classification of reaction to fire	<p>HKL B5.1/HKL B5.2/HKL B5.3/B8.2</p> <p>EN 13823 EN ISO 11925-2 EN 13501-1 EN ISO 1716</p>	HAPS

Annex to declaration of accreditation (scope of accreditation)
 Normative document: EN ISO/IEC 17025:2017
 Registration number: **L 505**

of **Peutz B.V.**
Laboratorium voor Brandveiligheid

This annex is valid from: **05-07-2023** to **01-03-2024**

Replaces annex dated: **08-02-2023**

Decision 2011/246/EC				
DOORS, WINDOWS, SHUTTERS, BLINDS, GATES AND RELATED BUILDING HARDWARE (1/1)		EN 16034: 2014; EN 1935:2002; EN 1935:2002/AC:2003		
36.	Doors and gates (with or without related hardware) (fire/smoke compartmentation and on escape routes) Windows (with or without related hardware) (fire/smoke compartmentation and on escape routes) Building hardware related to doors, gates and windows (fire/smoke compartmentation and on escape routes)	Testing and classification of fire resistance	HKL B3.1/HKL B6.1/HKL B8.1 EN 1634-1 EN 1634-3 EN 13501-2	HAPS