Annex to declaration of accreditation (scope of accreditation)
Normative document: EN ISO/IEC 17025:2017
Registration number: **L 627**

of **Royal SMIT Transformers B.V.**
**Trading as AOL**

This annex is valid from: **01-07-2026** to **01-10-2029** Replaces annex dated: **24-07-2025**

## Location(s) where activities are performed under accreditation

### Head Office

Groenestraat 336
6531 JC
Nijmegen
The Netherlands

| Location | Abbreviation/ location code |
|---|---|
| Groenestraat 336<br>6531 JC<br>Nijmegen<br>The Netherlands | NMN |

| No. | Material or product | Type of activity[1] | Internal reference number | Location |
|---|---|---|---|---|
| 1 | Insulating liquids | Determination of the dielectric dissipation factor; 90°C (dielectric dissipation factor and resistivity 90°C) | 29.20.50-04.010<br>IEC 60247 | NMN |
| 2 | | Determination of the breakdown voltage | 29.20.50-04.008<br>IEC 60156 | NMN |
| 3 | | Determination of free and dissolved gasses; GC-FID and GC-TCD<br><br>$H_2$, $CH_4$, $C_2H_6$, $C_2H_4$, $C_2H_2$, $C_3H_8$, $C_3H_6$, *i*-$C_4H_{10}$, *n*-$C_4H_{10}$, CO and $CO_2$ | 29.20.50-04.002 & .005<br>IEC 60567 | NMN |
| 4 | | Determination of interfacial tension; ring method | 29.20.50-04.018<br>ASTM D971 | NMN |

This annex has been approved by the Board of the Dutch Accreditation Council, on its behalf,

J.A.W.M. de Haas

[1] If there is a referral to a code starting with NAW, NAP, EA or IAF, this concerns a scheme mentioned on the RvA-BR010-lijst.
If no date or version number is mentioned for a normative document, the accreditation concerns the most current version of the document or scheme.

Annex to declaration of accreditation (scope of accreditation)
Normative document: EN ISO/IEC 17025:2017
Registration number: **L 627**

of **Royal SMIT Transformers B.V.**
**Trading as AOL**

This annex is valid from: **01-07-2026** to **01-10-2029** Replaces annex dated: **24-07-2025**

| No. | Material or product | Type of activity[1] | Internal reference number | Location |
|---|---|---|---|---|
| 5 | Insulating liquids | Determination of PCBs; GC-ECD<br>PCB-28, PCB-52, PCB-101, PCB-118, PCB-138, PCB-153 en PCB-180 | 29.20.50-04.004<br>in-house method | NMN |
| 6 | | Determination of water; coulometric Karl Fischer titration | 29.20.50-04.001<br>IEC 60814 | NMN |
| 7 | | Determination of acidity; potentiometric titration | 29.20.50-04.011<br>IEC 62021-1 | NMN |